



Punjab Fire Services
(Amritsar MC)



FIRE SAFETY CERTIFICATE
Fire Safety Certificate

NOC No **107-105164-Fire/80034**

NOC Type: **Renew**

Dated **21-Dec-2024**

Certified that the **St Soldier Elite Convent School** at **Chawinda Devi Amritsar** comprised of **0** basements and **3** (Upper floor) owned/occupied by **SHARANJIT EDUCATIONAL SOCIETY** have compiled with the fire prevention and fire safety requirements of National Building Code and verified by the officer concerned of fire service on **21-Dec-2024** in the presence of **Parveen Sharma** (Name of the owner or his representative) and that the building / premises is fit for occupancy group **Group-B** subdivision **B-1** (As per NBC) for a period of **one year** from issue date. Subject to the following conditions.

Issued on **21-Dec-2024** at **Amritsar MC**

It is certified that **St Soldier Elite Convent School**, **Chawinda Devi, Amritsar**, comprising **0** Basement and **3** (Upper Floor) owned/occupied by **SHARANJIT EDUCATIONAL SOCIETY**, is fire-fighting and safety compliant as per National Building Code as certified by the concerned Fire Officer on **21-Dec-2024** and is eligible for occupancy by **Parveen Sharma** (Name of Owner or his/her representative) and the building/building is eligible for occupancy. Occupancy Group **Group-B** subdivision **B-1** (as per N.B.C.) for **one year** from the effective date. For which the instructions are as follows.

Release date **21-Dec-2024** Where **Amritsar MC**.

1. Fire Safety arrangements shall be kept in working condition at all the times.
Fire safety devices should be kept operational/in good condition at all times.
2. No, alteration/ addition/ change in use of occupancy is allowed.
Any kind of alteration/extension/change in occupancy is prohibited.
3. Occupants/owners should have trained staff to operate the operation of fire safety system provided therein.
Ensure that residents/owners are made aware of the use of available fire extinguishers.
4. Fire Officer can check the arrangements of fire safety at any time, this certificate will be withdrawn without any notice if any deficiency is found.
The fire brigade officer can check all these arrangements at any time, if any deficiency is found, then this certificate will be considered cancelled without any notice.
5. Occupants/owners should apply for renewal of fire safety certificate one month prior to expiry of this certificate.
The owner will be required to renew the issued fire safety certificate one month before its expiry date.

*** Above details cannot be used as proof of ownership.**

The information provided above will not be used as proof of ownership.

*** This is a digitally created certificate, no signature is needed**

This is a digitally (computerized) generated certificate, which does not require a signature.

**PROFORMA FOR THE SAFETY OF SCHOOL BUILDING
PART- 1**

(To be filled by the Head of School/ Institute)

1. Name of the School **ST. SOLDIER ELITE CONVENT SCHOOL**
2. Location **CHAWINDA DEVI** :
3. Plot Area **2.01 ACRES** :
4. Plinth Area **3852.48 sqm** :
5. Number of Storey's :
6. Year of Construction of Building **Basement = 8844.38 + G.F = 10869.39 + F.F = 10869.39
+ S.F. = 10869.39 TOTAL = 41452.55**
7. **If the building has been constructed under the supervision
Of the qualified Engineer, the following details may be given** :
 - a) Name of the Engineer with qualification **S. DARSHARAJIT SINGH**
 - b) Address of Engineer **MANAWALA** :
 - c) Set of Structural drawings used in the construction, if available :
 - d) Name & address of Architect with qualification **S. NARINDER SINGH
REGD - ARCHITECT 2441**
8. **Whether the building has been constructed for the purpose** :
 - a) School : **YES/ NO** ✓
 - b) Residential Purpose and converted for use as a School : **YES/ NO** ✓
9. **Materials used for roofs** :
 - a) R.C.C. Slabs/R.B.C. Slabs : **YES/ NO** ✓
 - b) R.S. Joist & Battons : **YES/ NO** ✓
 - c) Wooden joists & Battons : **YES/ NO** ✓
10. **Materials used for walls** :
 - a) Mud Mortar : **YES/ NO** ✓
 - b) Cement Mortar : **YES/ NO** ✓
 - c) Lime Mortar : **YES/ NO** ✓
11. **Flooring** :
 - a) Conglomerate : **YES/ NO** ✓
 - b) Terrazo : **YES/ NO** ✓
 - c) Brick Paving. : **YES/ NO** ✓
12. **A detailed drawing indicating dimensions of the rooms
Alongwith size and location of doors and windows
(Attached)**

13. FOR FIRE SAFETY

- a) Whether the width of the staircase is 1.5 mtr.
- b) Whether portable fire extinguisher exists.
- c) Whether school building is free from inflammable & toxic material.
- d) Whether cooking of food is done at a safe place.
- e) Whether any Thatch or combustible material has used

Yes/No ✓
Yes/No ✓
Yes/No ✓
Yes/No ✓
Yes/No ✓

14. Requirement for fire protection arrangement under

NB-Part-IV

(For Building height less than 15 metre)

- a) Whether Hose Reel provides.
- b) Whether down comer provided.
- c) Whether Automatic sprinkler provided.
- d) Whether underground static water tank of capacity.
50000Ltr.(if covered area exceeds 1500sqm)
- e) Where over head tank of capacity 10000 Ltr. Exists
(in case of hose reel) 20000Ltr.
- f) Whether one electric and one diesel pump of 3 kg/cum
pressure of capacity 1620 LPM, one electric pump of capacity
180 LPM exist near underground static tank.
- g) Whether a pump 3 kg/cum pressure & 450/500
LPM Exist near overhead tank

Yes/No ✓
Yes/No ✓
Yes/No ✓
Yes/No ✓
Yes/No ✓

Yes/No ✓
Yes/No ✓


**Signature of the head of school/
Institute**